

3745-18-49

Lake county emission limits.

[Comment: For dates and availability of non-regulatory government publications, publications of recognized organizations and associations, federal rules, and federal statutory provisions referenced in this rule, see paragraph (C) of rule 3745-18-01 of the Administrative Code titled "referenced materials."]

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 7.2 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Lubrizol Corporation" (OEPA premise number 0243000024) or any subsequent owner or operator of the "Lubrizol Corporation, 155 Freedom Road, Painesville, Ohio" shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
- (1) Boiler numbers 1 through 4 (OEPA source numbers B001 through B004); a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
 - (2) Process "C" (OEPA source number P001); a maximum of 19.05 pounds of sulfur dioxide per hour.
 - (3) Process "G" (OEPA source number P006); a maximum of 26.99 pounds of sulfur dioxide per hour.
 - (4) Process "L" (OEPA source number P011); a maximum of 2.4 pounds of sulfur dioxide per hour.
 - (5) Process "M" (OEPA source number P012); a maximum of 160.0 pounds of sulfur dioxide per hour.
 - (6) Process "N" (OEPA source number P013); a maximum of 25.0 pounds of sulfur dioxide per hour.
 - (7) Process "O" (OEPA source number P014); a maximum of 10.0 pounds of sulfur dioxide per hour.
 - (8) Process "W" (OEPA source number P022); a maximum of 20.0 pounds of sulfur dioxide per hour.
 - (9) Process "B" (OEPA source number P026); a maximum of 29.62 pounds of

sulfur dioxide per hour.

- (10) Process "Z" (OEPA source number P029); a maximum of 68.80 pounds of sulfur dioxide per hour.
 - (11) Process "AC" (OEPA source number P030); a maximum of 30.0 pounds of sulfur dioxide per hour.
 - (12) Waste incinerator (OEPA source number N001); a maximum of 100.0 pounds of sulfur dioxide per hour.
 - (13) In addition to the provisions of paragraphs (B)(4), (B)(5), (B)(6), (B)(7), (B)(8) and (B)(11) of this rule, processes "L", "M", "N", "O", "W" and "AC" (OEPA source numbers P011 through P014, P022 and P030) shall be limited to the emission of sulfur dioxide not to exceed a maximum of 247.4 pounds of sulfur dioxide per hour or a maximum of 100.0 tons of sulfur dioxide per calendar year.
 - (14) The combined allowable emissions from processes "L", "M", "N", "O", "W" and "AC" (OEPA source numbers P011 through P014, P022 and P030) for any hour shall be the sum of the individual allowable sulfur dioxide emission limits for those processes that are in operation during any part of that hour.
- (C) [Reserved].
- (D) The "PET Processors, LLC" (OEPA premise number 0243000165) or any subsequent owner or operator of the "PET Processors, LLC, 750 Bacon Road, Painesville, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 7300071 and 8300073 (OEPA source numbers B001 and B002) to exceed 0.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler and shall operate said boilers such that their combined average operating rate shall not exceed one hundred six MM Btu per hour for any calendar day.
 - (E) The "Carmeuse Lime, Inc." (OEPA premise number 0243030257) or any subsequent owner or operator of the "Carmeuse Lime, Inc., Williams Street, Grand River, Ohio" shall not cause or permit the emission of sulfur dioxide from lime kiln numbers 4 and 5 (OEPA source numbers P001 and P002) to exceed a maximum of 10.0 pounds of sulfur dioxide per ton of product.
 - (F) The "Painesville Municipal Electric Plant" (OEPA premise number 0243110008) or any subsequent owner or operator of the "Painesville Municipal Electric Plant, 325 Richmond Street, Painesville, Ohio" shall ~~not cause or permit the emission of sulfur~~

~~dioxide from~~ meet the following for boiler numbers 3, 4 and 5 (OEPA source numbers ~~B001~~B005, ~~B003~~B003, and ~~B004~~B004): to

- (1) Not cause or permit the emission of sulfur dioxide to exceed a maximum of ~~5.74.0~~ pounds of sulfur dioxide per MM Btu actual heat input from each boiler and shall operate said boilers such that their combined average operating rate shall not exceed five hundred ninety three MM Btu per hour for any calendar day.
 - (2) Operate said boilers such that their combined average operating rate shall not exceed two hundred forty-nine MM Btu per hour for any calendar day.
 - (3) Operate only one boiler at any time, except during periods of start-up and shutdown.
 - (4) Operate boiler number 3 (OEPA source number B003) such that the average rate shall not exceed seventy-two MM Btu per hour for any thirty-day period.
 - (5) Operate boiler number 4 or 5 (OEPA source numbers B004 and B001) such that the average rate shall not exceed eighty-five MM Btu per hour for any thirty-day period.
 - (6) Comply with the requirements for a "limited use boiler" as defined in 40 CFR 63.7575 at each boiler, which requires a federally enforceable annual capacity factor of no more than ten per cent, in accordance with 40 CFR 63.7500 and 40 CFR 63.7540.
- (G) ~~The "Cleveland Electric Illuminating Company, Eastlake Plant" (OEPA premise number 0243160009) or any subsequent owner or operator of the "Cleveland Electric Illuminating Company, Eastlake Plant, 10 Erie Road, Willoughby, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 5 (OEPA source numbers B001 through B005) to exceed a maximum of 5.64 pounds of sulfur dioxide per MM Btu actual heat input from each boiler~~[Reserved].
- (H) [Reserved].
- (I) The "Lincoln Electric Company" (OEPA premise number 0243080843) or any subsequent owner or operator of the "Lincoln Electric Company, Heisley Road, Mentor, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler number 1 (OEPA source number B001) to exceed a maximum of 3.8 pounds of sulfur dioxide per MM Btu actual heat input.

Effective:

Five Year Review (FYR) Dates: 11/30/2015

Certification

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/79, 2/17/11