

**3745-82-01      Definitions.**

As used in this chapter of the Administrative Code:

- (A) Except as otherwise noted, the definitions in rule 3745-81-01 of the Administrative Code shall apply to this chapter.
- (B) "Secondary maximum contaminant level" means the advisable maximum level of a contaminant in water which is delivered to the free-flowing outlet of the ultimate user of a public water system. Contaminants added to the water under circumstances controlled by the user, except those resulting from corrosion of piping and plumbing caused by water quality, are excluded from this definition.

Effective: 10/01/2006

R.C. 119.032 review dates: 03/17/2011 and 03/17/2016

Promulgated Under: 119.03

Statutory Authority: 6109.04

Rule Amplifies: 6109.01, 6109.03, 6109.04

Prior Effective Dates: 11/26/80