

3745-91-09 Iron and manganese treatment.

- (A) New community water systems shall provide treatment for removal of:
 - (1) Iron to meet the secondary maximum contaminant level set forth in rule 3745-82-02 of the Administrative Code when the level of iron in water entering the water plant exceeds the secondary maximum contaminant level; and
 - (2) Manganese to meet the secondary maximum contaminant level set forth in rule 3745-82-02 of the Administrative Code when the level of manganese in water entering the water plant exceeds the secondary maximum contaminant level.

- (B) Existing community water systems, which develop a new source, or change a source shall provide treatment for:
 - (1) Iron, if the level of iron at the entry point to the distribution system increases and exceeds the secondary maximum contaminant level set forth in rule 3745-82-02 of the Administrative Code; and
 - (2) Manganese, if the level of manganese at the entry point to the distribution system increases and exceeds the secondary maximum contaminant level set forth in rule 3745-82-02 of the Administrative Code.

Replaces: 3745-91-09

Effective date: 01/01/2002

R.C. 119.032 review dates: 03/17/2011 and 03/17/2016

Promulgated under: R.C. Chapter 119

Statutory Authority: R.C. 6109.04

Rule amplifies: R.C. 6109.01, 6109.03

Prior Effective Dates: 11/26/80