

**3745-95-05 Type of protection required.**

- (A) The type of protection required under paragraphs (A), (B), (C) and (D) of rule 3745-95-04 of the Administrative Code shall depend on the degree of hazard which exists as follows:
- (1) An approved air gap separation shall be installed where a public water system may be contaminated with substances that could cause a severe health hazard;
  - (2) An approved air gap separation, an approved reduced pressure principle backflow prevention assembly or an approved reduced pressure detector check assembly shall be installed where a public water system may be contaminated with any substance that could cause a system or health hazard;
  - (3) An approved air gap separation, an approved reduced pressure principle backflow prevention assembly, an approved reduced pressure principle-detector check assembly, an approved double check valve assembly or an approved double check-detector check valve assembly shall be installed where a public water system may be contaminated with any substance that could cause a pollutional hazard.
- (B) The type of protection required under paragraph (E) of rule 3745-95-04 of the Administrative Code shall be an approved air gap separation or an approved interchangeable connection.
- (C) Where an auxiliary water system is used as a secondary source of water for a fire protection system, the provisions of paragraph (B) of this rule for an approved air gap separation or an approved interchangeable connection may be waived by the director, provided:
- (1) At premises where the auxiliary water system may be contaminated with substances that could cause a system, health or severe health hazard, a public water system or a consumer's water system shall be protected against backflow by installation of an approved reduced pressure principle backflow prevention assembly or an approved reduced pressure principle-detector check assembly;
  - (2) At all other premises, a public water system or a consumer's water system shall be protected against backflow by installation of an approved reduced pressure principle backflow prevention assembly, an approved reduced pressure principle-detector check assembly, an approved double check valve assembly or an approved double check-detector check valve assembly;
  - (3) A public water system or a consumer's water system shall be the primary

source of water for the fire protection system;

- (4) The fire protection system shall be normally filled with water from a public water system or a consumer's water system; and
- (5) The water in the fire protection system shall be used for fire protection only, with no other use of water from the fire protection system downstream from the approved backflow prevention device.

Effective: 05/01/2003

R.C. 119.032 review dates: 01/07/2013 and 01/07/2018

Promulgated Under: 119.03

Statutory Authority: 6109.04

Rule Amplifies: 6109.01, 6109.03, 6109.04, 6109.13

Prior Effective Dates: 7/1/72, 11/26/80