

**3745-279-22 Used oil storage requirements for generators.**

Used oil generators are subject to all applicable spill prevention, control and countermeasures (40 CFR Part 112) in addition to the requirements of rules 3745-279-20 to 3745-279-24 of the Administrative Code. Used oil generators are also subject to the underground storage tank standards (Chapter 1301:7-9 of the Administrative Code) for used oil stored in underground tanks whether or not the used oil exhibits any characteristics of hazardous waste, in addition to the requirements of rules 3745-279-20 to 3745-279-24 of the Administrative Code.

- (A) Storage units. Used oil generators must store used oil in tanks, as defined in rule 3745-279-01 of the Administrative Code; in containers, as defined in rule 3745-279-01 of the Administrative Code; or in units subject to regulation under Chapters 3745-54 to 3745-57 and 3745-205 or Chapters 3745-65 to 3745-69 and 3745-256, and Chapter 3745-270 of the Administrative Code.
- (B) Condition of units. Containers and aboveground tanks used to store used oil at generator facilities must be:
  - (1) In good condition (no severe rusting, apparent structural defects or deterioration); and
  - (2) Not leaking (no visible leaks).
- (C) Labels.
  - (1) Containers and aboveground tanks used to store used oil at generator facilities must be labeled or marked clearly with the words "Used Oil."
  - (2) Fill pipes used to transfer used oil into underground storage tanks at generator facilities must be labeled or marked clearly with the words "Used Oil."
- (D) Response to releases. Upon detection of a release of used oil to the environment that is not subject to the requirements of Chapter 1301:7-9 of the Administrative Code and which has occurred after October 20, 1998, a generator must perform the following cleanup steps:
  - (1) Stop the release;
  - (2) Contain the released used oil;
  - (3) Clean up and manage properly the released used oil and other materials; and
  - (4) If necessary, repair or replace any leaking used oil storage containers or tanks prior to returning them to service.

[Comment: For dates of non-regulatory government publications, publications of recognized organizations and associations, federal rules, and federal statutory provisions referenced in this rule, see rule 3745-50-11 of the Administrative Code titled "Incorporated by reference."]

Effective: 12/07/2004

119.032 review dates: Exempt

Promulgated under: 119.03

Statutory authority: 3734.12

Rule amplifies: 3734.12

Prior effective dates: 10/20/1998, 12/07/2000