

3745-66-95

Inspections.

(A) The owner or operator must inspect, where present, at least once each operating day: data gathered from monitoring and leak-detection equipment (e.g., pressure or temperature gauges, monitoring wells) to ensure that the tank system is being operated according to its design.

(B) Except as noted under paragraph (C) of this rule, the owner or operator must inspect at least once per operating day:

(1) Overfill/spill control equipment (e.g., waste-feed cutoff systems, bypass systems, and drainage systems) to ensure that it is in good working order;

(2) ~~The aboveground~~Above ground portions of the tank system, if any, to detect corrosion or releases of waste; and

~~(3) Data gathered from monitoring equipment and leak-detection equipment (e.g., pressure and temperature gauges, monitoring wells) to ensure that the tank system is being operated according to its design; and~~

~~(4)~~(3) The construction materials and the area immediately surrounding the externally accessible portion of the tank system including secondary containment structures (e.g., dikes) to detect erosion or signs of releases of hazardous waste (e.g., wet spots, dead vegetation).

[~~Note~~Comment: Paragraph (C) of rule 3745-65-15 of the Administrative Code requires the owner or operator to remedy any deterioration or malfunction he finds. Rule 3745-66-96 of the Administrative Code requires the owner or operator to notify the director within twenty-four hours of confirming a release. Also, 40 CFR ~~part~~Part 302 may require the owner or operator to notify the "National Response Center" of a release.]

(C) Owners and operators of tank systems that either use leak detection equipment to alert facility personnel to leaks, or implement established workplace practices to ensure leaks are promptly identified, must inspect at least weekly those areas described in paragraphs (B)(1) to (B)(3) of this rule. Use of the alternate inspection schedule must be documented in the facility's operating record. This documentation must include a description of the established workplace practices at the facility.

(D) Reserved.

(E) Ancillary equipment that is not provided with secondary containment, as described in paragraphs (F)(1) to (F)(4) of rule 3745-66-93 of the Administrative Code, must be inspected at least once each operating day.

~~(B)~~(F) The owner or operator must inspect cathodic protection systems, if present, according to, at a minimum, the following schedule, to ensure that they are functioning properly:

- (1) The proper operation of the cathodic protection system must be confirmed within six months after initial installation and annually thereafter; and
- (2) All sources of impressed current must be inspected and/or tested, as appropriate, at least bimonthly (i.e., every other month).

[~~Note~~Comment: The practices described in the "National Association of Corrosion Engineers (NACE)" standard, "Recommended Practice (RP-02-85) - Control of External Corrosion on ~~Metallic~~Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems," and the "American Petroleum Institute (API)" publication 1632, "Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems," may be used, where applicable, as guidelines in maintaining and inspection of cathodic protection systems.]

~~(E)~~(G) The owner or operator must document in the operating record of the facility an inspection of those items in paragraphs (A) and (B) to (B)(3) of this rule.

Effective: 09/05/2010

R.C. 119.032 review dates: 04/14/2010 and 08/25/2014

CERTIFIED ELECTRONICALLY

Certification

07/23/2010

Date

Promulgated Under: 119.03
Statutory Authority: 3734.12
Rule Amplifies: 3734.12
Prior Effective Dates: 04/15/1981, 01/07/1983, 12/08/1988, 12/30/1989