

*** DRAFT – NOT FOR FILING ***

3745-512-460

Tanks.

(A) The owner or operator shall visually inspect each tank to identify any leak, repair each leak found, and test the repair. Testing shall use air pressure at twice the hydrostatic pressure at the bottom of the tank when the tank is full.

(B) Certification of each tank by the owner or operator shall include the following:

(1) Record drawings depicting the location of the tank and spill containment, as constructed.

(2) Record drawings showing the details of the tank, spill containment, and load-out facilities, as constructed.

(3) Results of all testing and verification that the tank meets the standards in paragraph (A) of this rule and the specifications in the authorizing document.